

Energy Efficiency Measures				Electric Savings			Fuel Savings			\$ Savings & Cost		
EEM #	Measure Status	EEM Category	EEM Description	kWh	kW	Electric Cost Savings	Fuel Type	Fuel MMBtu Savings	Fuel Cost Savings	Total Annual Savings	Install Costs	Simple Payback (years)
EEM-1	R	Lighting	Interior Lighting Retrofit	73	0.1	\$ 13	Oil - No. 2	(0)	(\$ 5)	\$ 8	\$ 180	23.6
EEM-2	RNE	Envelope	Building Airflow Reduction	0	0.0	\$ 0	Oil - No. 2	10	\$ 426	\$ 426	\$ 9,720	22.8
EEM-3	RNE	Envelope	Insulate Building Envelope (Roof)	0	0.0	\$ 0	Oil - No. 2	8	\$ 356	\$ 356	\$ 12,996	36.6
EEM-4	R	Envelope	Install Storm Windows	0	0.0	\$ 0	Oil - No. 2	20	\$ 860	\$ 860	\$ 4,742	5.5
EEM-5	R	HVAC	Install Duct Insulation	0	0.0	\$ 0	Oil - No. 2	2	\$ 78	\$ 78	\$ 287	3.7
EEM-6	R	Envelope	Install Insulated Doors	0	0.0	\$ 0	Oil - No. 2	4	\$ 192	\$ 192	\$ 1,800	9.4
EEM-7	R	HVAC	Replace Hvac System With Rooftop Heat Pump	(8,558)	(0.6)	(\$ 1,523)	Oil - No. 2	109	\$ 4,736	\$ 3,213	\$ 7,500	2.3
EEM-8	R	Controls	Install Programmable Thermostat	0	0.0	\$ 0	Oil - No. 2	12	\$ 515	\$ 515	\$ 175	0.3
Total of Recommended Measures:				(8,485)	(0.4)	(\$ 1,510)		165	\$ 7,157	\$ 5,647	\$ 37,400	6.6